

**GENERAL REFERENCES FOR DRAWINGS:**

**REGION OF PEEL STANDARD DRAWINGS DELETED - NOVEMBER 2011 REVISION AND APRIL 2014 REVISION:**

DRAWING NUMBER	DRAWING TITLE	ORIGINAL DATE	REPLACED WITH NEW REGION OF PEEL STANDARD DRAWING	REPLACED WITH OPSD
1-1-1	CIRCULAR PRECAST CHAMBER	MAY 2009	1-1-5, 1-1-7	
1-1-2	SMALL CAST-IN-PLACE CHAMBER	MAY 2009	1-1-6	
1-1-3	750/900 DIA. WM. VALVE AND CHAMBER (CAST-IN-PLACE)	MAY 2009	1-1-6, 1-3-27 TO 1-3-40	
1-1-4	RECTANGULAR PRECAST CHAMBER	MAY 2009	1-1-6	
1-2-2	STANDARD HEAVY DUTY FRAME AND COVER	MAY 2009		401.030
1-2-5	STANDARD CHAMBER STEPS ALUMINUM	MAY 2009		405.020
1-3-3A	RESTRAINING OF 300mm DIAMETER AND SMALLER P.V.C. WATERMAIN AT IN-LINE VALVE	NOV. 2011	1-5-9	
1-3-5	AIR VALVE AND CHAMBER	APRIL 2009	1-1-5, 1-3-12, 1-3-13, 1-3-14	
1-3-6	DRAIN VALVE AND CHAMBER	MAY 2009	1-1-6, 1-3-15, 1-3-27, 1-3-28, 1-3-29	
1-3-7	VALVE SETTING FOR 400mm TO 600mm PIPE	MAY 2009	1-1-6, 1-3-18 TO 1-3-24	
1-3-10	PRESSURE ZONE BOUNDARY VALVE	MAY 2009	1-1-5, 1-3-16	
1-5-2	WATERMAIN SUPPORT BRIDGING DISTURBED GROUND	MAY 2009	N/A - As Per Contract Design	
1-5-3	CONCRETE THRUST COLLAR	MAY 2009	N/A - As Per Contract Design	
1-7-5	SWABBING OUTLET 100mm AND LARGER	MAY 2009	1-7-9	
1-3-23	TYPICAL LINE VALVE CHAMBER FOR 600 CPP WITH ISOLATION VALVE, DOUBLE DRAIN VALVE AND COMBINATION AIR RELEASE OR VACUUM VALVE	NOV. 2011	1-3-21, 1-3-22	

**ONTARIO PROVINCIAL STANDARD DRAWING REFERENCES TO BE READ IN CONJUNCTION WITH REGION OF PEEL STANDARD DRAWINGS - NOVEMBER 2011 REVISION AND APRIL 2014 REVISION**

DRAWING NUMBER	DRAWING TITLE
401.030	CAST IRON, SQUARE FRAME WITH CIRCULAR WATERTIGHT COVER FOR MAINTENANCE HOLES
402.030	CAST IRON, RECTANGULAR FRAME WITH TWO PIECE COVER FOR METER AND VALVE CHAMBERS
404.020	ALUMINUM SAFETY PLATFORM FOR CIRCULAR MAINTENANCE HOLES
404.022	ALUMINUM SAFETY PLATFORM FOR 1800mm CIRCULAR MAINTENANCE HOLES WITH DROP PIPE
405.020	MAINTENANCE HOLE STEPS SOLID
406.010	ALUMINUM LADDER FOR MAINTENANCE HOLES
704.010	PRECAST CONCRETE ADJUSTMENT UNITS FOR MAINTENANCE HOLES, CATCH BASINS AND VALVE CHAMBERS
1101.019	PRECAST CONCRETE VALVE CHAMBER WITH POURED-IN-PLACE THRUST BLOCKS 2400 x 3000mm CHIMNEY AND CAP
1101.020	VALVE OPERATOR
1109.010	CATHODIC PROTECTION FOR METALLIC WATERMAIN SYSTEMS

NOTE: THIS LIST INCLUDES OPSD REFERENCES THAT APPLY DIRECTLY TO THE NEW AND REVISED REGION OF PEEL STANDARD DRAWINGS, BUT IT DOES NOT PRECLUDE THE APPROVED USE OF ANY APPLICABLE OPSD REFERENCES NOT LISTED ABOVE.

**GENERAL NOTES FOR PRECAST CONCRETE CHAMBERS:**

- ALL PRECAST CHAMBERS TO BE SUPPLIED BY A MANUFACTURER CERTIFIED UNDER THE OCPA PLANT PREQUALIFICATION PROGRAM.
- SUBMIT SHOP DRAWINGS TO THE CONTRACT ADMINISTRATOR FOR INFORMATION. ALL DRAWINGS SHALL BEAR THE SIGNATURE AND SEAL OF A PROFESSIONAL ENGINEER LICENSED TO PRACTISE IN ONTARIO.
- THE MANUFACTURER SHALL PROVIDE LETTERS SIGNED BY A PROFESSIONAL ENGINEER CERTIFYING THE FOLLOWING:
  - THAT THE DESIGN OF THE PRECAST UNITS MEETS THE REQUIREMENTS OF THE SPECIFICATIONS
  - THAT THE PRECAST UNITS HAVE BEEN MANUFACTURED AS PER DESIGN AND INSPECTED IN ACCORDANCE WITH THE PLANT PREQUALIFICATION PROGRAM
- PROVIDE CONCRETE WITH MINIMUM STRENGTH OF 35 MPa UNLESS A HIGHER STRENGTH IS REQUIRED BY THE MANUFACTURER OR DESIGNER.
- REINFORCING STEEL SHALL BE IN ACCORDANCE WITH CSA G30.18 WITH A MINIMUM YIELD STRENGTH OF  $F_y=400$  MPa.
- REFER TO STANDARD DRAWINGS 1-1-5, 1-1-6, 1-1-7, 1-1-8, 1-2-1, 1-2-4, 1-2-6 AND 1-2-7 AND ONTARIO PROVINCIAL STANDARD DRAWINGS FOR CHAMBER DETAILS PERTAINING TO WATERPROOFING, JOINT SEALING, ADJUSTMENT UNITS, FRAME & COVERS, CHAMBER STEPS AND LADDERS, INSULATION, FROST STRAPS, VALVE STEM EXTENSION AND BRACKETS, SUMPS, VALVE AND PIPE SUPPORTS.
- ALL PRECAST COMPONENTS SHALL BE DESIGNED AND MANUFACTURED TO CSA STANDARD A23.3 AND CSA STANDARD A23.4. FURTHER, ALL PRECAST CHAMBER COMPONENTS, INCLUDING ACCESS HATCHES AND TOP SLABS, SHALL ALSO MEET THE REQUIREMENTS OF CSA STANDARD S6 (CANADIAN HIGHWAY BRIDGE CODE).

**GENERAL NOTES FOR PIPING:**

- MECHANICAL THRUST RESTRAINT DESIGN AND SPACING SHALL BEAR THE SIGNATURE AND SEAL OF A PROFESSIONAL ENGINEER LICENSED TO PRACTISE IN ONTARIO.
- SUBMIT CONCRETE PRESSURE PIPE SHOP DRAWINGS TO THE CONTRACT ADMINISTRATOR FOR INFORMATION. ALL DRAWINGS SHALL BEAR THE SIGNATURE AND SEAL OF A PROFESSIONAL ENGINEER LICENSED TO PRACTISE IN ONTARIO.
- ALL PIPING, FITTINGS, VALVES, APPURTENANCES AND MECHANICAL RESTRAINTS TO BE c/w DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.



**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: APRIL 2014

APPROVED BY

DRAWN BY

A.P.

AINLEY GROUP

**GENERAL NOTES AND REFERENCES**

STD. DWG. NUMBER

SCALE

**1-1-0**

N.T.S.