



NOTE

1. VALVE TO BE RESTRAINED AS SHOWN IN STD. 1-5-9.
2. TRACER WIRE TO BE INCLUDED.
3. ALL PIPING, FITTINGS, VALVES, APPURTENANCES AND MECHANICAL RESTRAINTS TO BE PROTECTED WITH 3 PART CORROSION PROTECTION SYSTEM, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: MARCH 2018

APPROVED BY

DRAWN BY

E.O.

AINLEY GROUP

STD. DWG. NUMBER

SCALE

1-3-8

N.T.S.

**VALVE STEM EXTENSION IN VALVE BOX
FOR WATERMAIN 100mm TO 300mm DIA. INCLUSIVE**