



NOTE

1. 50mm GALVANIZED CONDUIT SHALL BE INSTALLED FROM CHAMBER WALL TO A SUITABLE LOCATION 2000 MIN. OUTSIDE TRAFFIC AREA.
2. IF SERVICE IS POLYETHYLENE, THEN BRASS ADAPTORS TO IRON PIPE THREAD SHALL BE SUPPLIED AND INSTALLED FOR METER INSTALLATON.
3. EXTRUDED COPPER (SOLDERED) OR GALVANIZED FITTINGS SHALL NOT BE USED, ALL FITTINGS TO BE BRASS.
4. FOR CORRECT METER INSTALLATION, METER SPACERS ARE AVAILABLE AT 2 COPPER RD. BRAMPTON. PHONE: (905) 791-5997 EXT. 3226
5. ALL INTERNAL AND EXTERNAL VALVES, FITTINGS, THROUGH WALL METAL PIPING AND MECHANICAL RESTRAINTS TO BE c/w DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: NOVEMBER 2011

APPROVED BY

DRAWN BY

A.L.

AINLEY GROUP

16 x 19 TO 25 METER IN CHAMBER

STD. DWG. NUMBER

SCALE

1-4-12

N.T.S.