



**NOTE**

1. PROVISION IS TO BE MADE FOR THE DISPOSAL OF WATER USED FOR IN PLACE TESTING OF COMPOUND METER EITHER THROUGH FLOOR DRAIN OR THE 125mm FERRULE.
2. BY-PASS MAY BE ONE PIPE SIZE SMALLER THAN METER SIZE AND MAY BE INSTALLED HORIZONTALLY.
3. WHERE METER ROOM IS NOT ADJACENT TO AN OUTSIDE WALL OR IS BELOW EXTERIOR FINISHED GRADE, THE APPLICANT/ CONTRACTOR SHALL PROVIDE A CONTINUOUS 12mm E.M.T. CONDUIT COMPLETE WITH NYLON FISH LINE FROM METER ROOM TO 1000mm ABOVE EXTERIOR FINISHED GRADE.
4. WHERE REQUIRED, BACKFLOW PREVENTOR SHALL BE INSTALLED AFTER BOTH THE METER AND BY-PASS



**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: NOVEMBER 2011

APPROVED BY

DRAWN BY

A.L.

AINLEY GROUP

**100mm - 250mm PROTECTUS III METER  
IN BUILDING**

STD. DWG. NUMBER

SCALE

**1-4-16**

N.T.S.