



**NOTE**

1. STONE TO BE COMPACTED IN 300 LIFTS.
2. FOR P.V.C. AND POLY WRAPPED DUCTILE IRON WATERMAIN, GRANULAR D TO BE USED OR CRUSHED STONE AND COMPACTED TO 100% STD. PROCTOR DENSITY.
3. COMPACTION TO 100% STANDARD PROCTOR DENSITY.
4. CAST IRON WATERMAIN TO BE REPLACED WITH D.I. PIPE AS PER STD. 1-5-2A.



**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: MAY 2009

APPROVED BY

DRAWN BY

A.P.

A.M.

STD. DWG. NUMBER

SCALE

**1-5-2**

N.T.S.

**WATERMAIN SUPPORT  
BRIDGING DISTURBED GROUND**