



NOTE

1. MINIMUM TRENCH WIDTH TO BE O.D. PLUS 600mm. MAX TRENCH WIDTH TO BE O.D. PLUS 750mm.
2. INSULATING THE BOTTOM OF THE TRENCH MAY BE REQUIRED UNDER CERTAIN CIRCUMSTANCES (i.e. OVER A CULVERT).