



NOTE

1. IF THE WATERMAIN IS NOT AT THE STANDARD OFFSET, THE LOCATION OF THE HYDRANT TO BE AS PER CONSTRUCTION DRAWINGS.
2. BACKFILL TRENCH WITH GRANULAR 'B' COMPACTED TO 100% STD. PROCTOR DENSITY.
3. MECHANICAL RESTRAINTS REQUIRED ON ALL PVC HYDRANT LATERALS INCLUDING VALVES AND FITTINGS AS PER REGION STANDARD DRAWING 1-5-9.
4. ALL PIPING, FITTINGS, VALVES, APPURTENANCES AND MECHANICAL RESTRAINTS TO BE PROTECTED WITH 3 PART CORROSION PREVENTION SYSTEM, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: MARCH 2018

APPROVED BY

DRAWN BY

E.O.

AINLEY GROUP

STD. DWG. NUMBER

SCALE

1-6-1

N.T.S.

**HYDRANT SETTING
FOR D.I. OR P.V.C. PIPE**