



NOTE

1. WHERE POSSIBLE, ALL DEAD END MAINS TO BE ELIMINATED BY LOOPING. IF THIS IS NOT POSSIBLE, TERMINATING WATERMANS AT A HYDRANT TEE SHOULD BE CONSIDERED.
2. ON 200mm AND LARGER WATERMANS, A TYTON PLUG TAPPED WITH 50mm I.P.T. HOLE MAY BE USED IN PLACE OF A MJ. CAP.
3. MECHANICAL RESTRAINT MUST BE PROVIDED FOR WATERMAIN OR MJ. FITTINGS (STD. DWG. 1-5-9).
4. ALL PIPING, FITTINGS, VALVES, APPURTENANCES AND MECHANICAL RESTRAINTS TO BE c/w DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.

Region of Peel
Working for you

**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: APRIL 2014

APPROVED BY

DRAWN BY

A.P.

AINLEY GROUP

STD. DWG. NUMBER

SCALE

1-7-3

N.T.S.

**50mm OFF END OF WATERMAIN
AT CUL-DE-SAC**