



NOTE: BRING TRACER WIRE UP TO HYDRANT FOR BOTH COPPER LOOP AND MAIN LINE PVC. DO NOT INTER-CONNECT

NOTE

1. PROVIDE 25mm DIA. SERVICE FOR LOTS.
2. FOR OFFSET OF WATERMAIN FROM STREET LINE, REFER TO THE LOCAL MUNICIPALITIES RELEVANT STANDARD CROSS-SECTION.
3. ZINC ANODE (Z-12-24) TO BE INSTALLED AS PER OPSS 442 - CONSTRUCTION SPECIFICATION FOR CORROSION PROTECTION OF NEW AND EXISTING WATERMAINS, AT 16m INTERVAL SPACING.



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: APRIL 2018

APPROVED BY

DRAWN BY

E.O.

AINLEY GROUP, TJ

STD. DWG. NUMBER

SCALE

1-7-4

N.T.S.

**TYPICAL 50mm WATERMAIN
ON CUL-DE-SAC**