



**NOTE**

1. INSTALL 50mm GALVANIZED CONDUIT FROM INSIDE CHAMBER WALL TO A SUITABLE LOCATION 2000mm MIN. BEYOND TRAFFIC AREA.
2. A CONTINUOUS FISH LINE TO BE INSTALLED THROUGH CONDUIT TO FACILITATE REMOTE READING DEVICE INSTALLATION.



**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: NOVEMBER 2011

APPROVED BY

DRAWN BY

A.P.

AINLEY GROUP

**REMOTE READING DEVICE INSTALLATION  
FOR CHAMBERS ONLY**

STD. DWG. NUMBER

SCALE

**1-2-3**

N.T.S.