



DELETED

**NOTE**

1. MAIN-LINE VALVE TO REMAIN IN CLOSED POSITION
2. CURB-STOP PLACED ON THE BY-PASS TO REMAIN IN THE OPEN POSITION AND BROUGHT FLUSH TO FINISHED GRADE
3. THIS SETUP TO BE USED FOR MINOR NON-ESSENTIAL WATERMANS, USUALLY LESS THAN 300mm Ø
4. TAPPING SADDLE TO BE USED ON PVC WATERMAIN.



**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: MAY 2009

APPROVED BY

DRAWN BY

**R.S.**

**P.W.**

STD. DWG. NUMBER

SCALE

**1-3-10**

**N.T.S.**

**PRESSURE ZONE BOUNDARY VALVE**