



NOTE

1. NO EXTRUDED COPPER FITTINGS (SOLDERED) OR GALVANIZED FITTINGS TO BE USED, ALL FITTINGS MUST BE MADE OF BRASS.
2. FOR CORRECT BY-PASS INSTALLATION, METER SPACERS ARE AVAILABLE AT 2 COPPER RD., BRAMPTON, PHONE:(905) 791-5997 EXT.3226.
3. INLET AND OUTLET PORTS TO BE MINIMUM 25mm
4. METER SUPPLIED AND INSTALLED BY THE REGION OF PEEL METER DEPARTMENT



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: JANUARY 2015

APPROVED BY

J.K.

DRAWN BY
AINLEY GROUP - 2011
UPDATED BY T.J.

STD. DWG. NUMBER

1-3-9

SCALE

N.T.S.

**25mm BY-PASS FOR
DETECTOR CHECK VALVE**