



**NOTE**

1. IF METER CHAMBER IS LOCATED NEAR THE STREET LINE, VALVE TO BE AT STREET LINE C/W SERVICE BOX.
2. 50mm GALVANIZED CONDUIT TO BE INSTALLED FROM INSIDE CHAMBER WALL TO A SUITABLE LOCATION 2000mm MIN. OUTSIDE TRAFFIC AREA, AS PER STD. DWG. 1-2-3.
3. IF OPTIONAL BYPASS IS NOT INSTALLED, THEN SHUTDOWN OF SERVICE WILL OCCUR FOR MAINTENANCE AND REPAIR DURING NORMAL BUSINESS HOURS.
4. EXTRUDED COPPER (SOLDERED) OR GALVANIZED FITTINGS SHALL NOT BE USED, ALL FITTINGS TO BE BRASS.
5. ALL INTERNAL AND EXTERNAL VALVES, FITTINGS, THROUGH WALL METAL PIPING AND MECHANICAL RESTRAINTS TO BE c/w DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.

**Region of Peel**  
Working for you

**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: NOVEMBER 2011

APPROVED BY

DRAWN BY

A.L.

AINLEY GROUP

**50mm TRU-FLO COMPOUND METER  
IN CHAMBER**

STD. DWG. NUMBER

SCALE

**1-4-19**

N.T.S.