



**NOTE**

1. IF METER CHAMBER IS LOCATED NEAR THE STREET LINE, VALVE TO BE AT STREET LINE.
2. 50mm GALVANIZED CONDUIT SHALL BE INSTALLED FROM INSIDE CHAMBER WALL TO A SUITABLE LOCATION 2000mm MIN. OUTSIDE VEHICLE TRAFFIC AREA, AS PER STD. DWG. 1-2-3.
3. BLIND FLANGE OR M.J. PLUG TAPPED TO SUIT.
4. BY-PASS MAY BE ONE SIZE SMALLER THAN METER SIZE
5. ALL INTERNAL AND EXTERNAL VALVES, FITTINGS, THROUGH WALL METAL PIPING AND MECHANICAL RESTRAINTS TO BE c/w DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.



**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: NOVEMBER 2011

APPROVED BY

DRAWN BY

A.L.

AINLEY GROUP

**75mm TRU-FLO COMPOUND METER  
IN CHAMBER**

STD. DWG. NUMBER

SCALE

**1-4-2**

N.T.S.