



NOTE

1. PROVISION IS TO BE MADE FOR THE DISPOSAL OF WATER USED FOR IN PLACE TESTING OF TRU-FLO COMPOUND METER EITHER THROUGH FLOOR DRAIN OR THE 125mm FERRULE.
2. IF HOT WATER TANK IS WITHIN 3.0m OF METER, THEN A CHECK VALVE IS REQUIRED BETWEEN THE METER AND HOT WATER TANKS.
3. BY-PASS MAY BE ONE PIPE SIZE SMALLER THAN METER SIZE AND MAY BE INSTALLED HORIZONTALLY.
4. WHERE METER ROOM IS NOT ADJACENT TO AN OUTSIDE WALL OR IS BELOW EXTERIOR FINISHED GRADE, THE APPLICANT/ CONTRACTOR SHALL PROVIDE A CONTINUOUS 12mm E.M.T. CONDUIT COMPLETE WITH NYLON FISH LINE FROM METER ROOM TO 1000mm ABOVE EXTERIOR FINISHED GRADE.
5. METER SHALL BE ACCESSIBLE AT ALL TIMES.
6. WHERE REQUIRED, BACKFLOW PREVENTOR SHALL BE INSTALLED AFTER BOTH THE METER AND BY-PASS



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: NOVEMBER 2011

APPROVED BY

DRAWN BY

A.L.

AINLEY GROUP

**100mm AND 150mm TRU-FLO
COMPOUND METER IN BUILDING**

STD. DWG. NUMBER

SCALE

1-4-3

N.T.S.