



**NOTE**

1. FOR D.I. PIPE USE A PIPE CLAMP FOR BONDING TO CONCRETE.
2. FOR CONC. PIPE ROUGH PIPE WALL FOR BONDING TO CONCRETE.
3. REINFORCED BARS TO HAVE 75mm CONC. COVER.

**Region of Peel**  
Working for you

**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: MAY 2009

APPROVED BY

DRAWN BY

A.M.

STD. DWG. NUMBER

SCALE

**1-5-3**

N.T.S.

**CONCRETE THRUST COLLAR**