



**BLOW-OFF SIZE TO MATCH THE SIZE OF THE FEED BASED ON STANDARD DRAWINGS 1-7-7 AND 1-7-8. WHERE A 100mm FEED IS REQUIRED CONTRACTOR TO PROVIDE AN INSTALLATION, INCLUDING ALL NECESSARY MATERIALS, TO RESPECT THE DESIGN CONCEPTS OF THIS STANDARD DRAWING.**

**NOTE**

1. VALVE BOX AND SERVICE BOX TO BE SET TO FINISHED GRADE.



**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: APRIL 2014

|                  |              |
|------------------|--------------|
| APPROVED BY      | DRAWN BY     |
| A.P.             | AINLEY GROUP |
| STD. DWG. NUMBER | SCALE        |
| <b>1-7-2</b>     | N.T.S.       |

**50mm BLOW-OFF FOR  
100mm AND LARGER WATERMAIN**