



**NOTE**

1. TWO STAINLESS STEEL (PASSIVE 304) TIE RODS MUST BE USED.
2. RETAINER GLAND RINGS ARE OPTIONAL BUT TIE RODS MUST BE USED.
3. TO BE DRAINED DURING WINTER MONTHS.
4. ALL JOINTS AND FITTINGS TO BE MECHANICALLY RESTRAINED.



**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: APRIL 2014

APPROVED BY

A.P.

STD. DWG. NUMBER

**1-7-5**

DRAWN BY

**AINLEY GROUP**

SCALE

**N.T.S.**

**TEMPORARY SWABBING/FLUSHING OUTLET  
100mm AND LARGER**