

MAINTENANCE HOLE FRAME PER STD. 2-2-3

13mm THREADED ROD (ST. STEEL)

BRICK OR MODULOC TO SUIT

ANCHOR

MAINTENANCE HOLE CONE SECTION

DELETED
(REFER TO SECTION 2-6)

NOTE

TWO ANCHORS REQUIRED PER FRAME AT OPPOSITE SIDES.



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: MAY 2009

REVISION NUMBER: FOR REVISION TRACKING REFER TO STD. DWG. 2-0-2

APPROVED BY

DRAWN BY

Y.C.

STD. DWG. NUMBER

SCALE

2-2-3B

N.T.S.

**DETAIL OF ANCHORING METHOD
FOR WATER TIGHT MAINTENANCE HOLE**