



DOUBLE GRAVITY SERVICE LATERAL ARRANGEMENT AT PROPERTY LINE

- NOTE**
1. MINIMUM TRENCH WIDTH TO BE 900mm.
 2. REFER TO STD. DWG. 2-3-1 FOR COVER AND BEDDING DETAILS.
 3. TEST FITTING TO BE MARKED "SAN".
 4. SANITARY PIPE TO BE GREEN IN COLOUR AND MINIMUM SDR 28.
 5. STORM CONNECTION TO BE ON THE LEFT WHEN FACING THE HOUSE.
 6. SANITARY CONNECTION MUST INCLUDE TEST FITTING AT PROPERTY LINE.
 7. SINGLE SANITARY SERVICE CONNECTIONS SHALL BE 125mm.
 8. SANITARY SEWER AND WATER CONNECTIONS TO BE LAID TO THE STREET LINE AS PER THE ABOVE STANDARD. THE REGION HAS NO OBJECTION TO THE EXTENSION OF THE SANITARY SEWER OR WATER CONNECTIONS BEYOND THE STREET LINE INTO THE PRIVATE SIDE. PRIVATE SIDE CONSTRUCTION IS UNDER LOCAL MUNICIPALITY JURISDICTION. LOCAL MUNICIPALITY IS RESPONSIBLE FOR STORM SEWERS AND SERVICES.
 9. WATERTIGHT, FACTORY MANUFACTURED PLUG/CAP DESIGNED FOR USE ON SPECIFIED PRE-SERVICED MATERIAL AND DIAMETER SHALL BE USED.



**PUBLIC WORKS
STANDARD DRAWING**

NEW RESIDENTIAL DEVELOPMENT CONNECTIONS

REV. DATE: AUGUST 2020

REVISION NUMBER: 2		FOR REVISION TRACKING REFER TO STD. DWG. 2-0-2	
APPROVED BY	DRAWN BY		
A.P.	AINLEY GROUP		
STD. DWG. NUMBER	SCALE		
2-4-4	N.T.S.		