



NOTE

1. METAL VALVE STANDS SHALL BE PLACED ON 3mm FIBREGLASS PADS, OR RUBBER PADS.
2. IF RESTRAINING RODS ARE REQUIRED IN WALL OR FLOOR SLEEVES, COAT THE RODS WITH COAL TAR EPOXY AND FILL VOID WITH NON-METALLIC EPOXY GROUT.
3. DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE NOTED.
4. VALVE CHAMBER TO BE CONSTRUCTED IN ACCORDANCE WITH REGION STANDARD.