



NOTES

- 1. THIS DRAWING MUST BE USED IN CONJUNCTION WITH STANDARD DRAWING 5-2-8A AND 5-2-6
- EXPANSION JOINTS ARE REQUIRED AT 6.0m INTERVALS AND:
 a) ADJACENT TO ABUTTING RIGID OBJECTS (UTILITY POLES, MAINTENANCE HOLES, VALVE BOXES ETC.)
 b) AT ALL CONSTRUCTION JOINTS
- 3. RELIEF JOINTS MUST HAVE A STANDARD SPACING OF 2.0m
- 4. ALL CONCRETE TO BE 32MPa; 7% +/- 1.5% AIR ENTRAINED

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.

