

2009 Design, Specifications & Procedures Manual Updates

Watermain Design Criteria

Section	Page	Description of Update
1	1	Introduction <ul style="list-style-type: none">- Note on minimum and maximum operating pressures added
2	3	Watermains General <ul style="list-style-type: none">- 14 gauge tracer wire replaced with 12 gauge TWU stranded copper, light colour plastic coated
2.8	7	Easements <ul style="list-style-type: none">- Addition of paragraph for permitted uses on easements
3.3	12	Valve Boxes and Chambers <ul style="list-style-type: none">- 14 gauge tracer wire replaced with 12 gauge TWU stranded copper, light colour plastic coated- Details for tracer wire attachment
3.4	12	Valve Box Protection <ul style="list-style-type: none">- New paragraph detailing watertight bolt down covers and venting
4.1	13	Numbers and Spacing <ul style="list-style-type: none">- Details for tracer wire and attachment
6.0	16	Water Services <ul style="list-style-type: none">- 12 gauge TWU stranded copper, light colour plastic coated
6.8	19	Planting Blocks <ul style="list-style-type: none">- 14 gauge tracer wire replaced with 12 gauge TWU stranded copper, light colour plastic coated