



FOR DETAILS OF SIGNALS FROM TYP. 7 TO 14 REFER TO DWG SPS-307.

- NOTES:**
1. VALVE ACTUATOR INTEGRATED CONTROL. BASED ON VALVE MAKE AND MODEL, IT MAY NOT REFLECT THE EXACT ARRANGEMENT OF INTEGRAL VALVE CONTROL, HOWEVER ALL VALVE ACTUATORS MUST PROVIDE SIMILAR FUNCTIONALITY SHOWN ON THIS DRAWING.
 2. REFER TO STANDARD GRINDER PANEL FOR ADDITIONAL DETAILS.
 3. ALL SIGNALS WITH IDENTIFIER ③ SIGNALS ARE TO BE CONNECTED TO ONE COMMON ISR PANEL.

<p>Region of Peel working with you</p>	PUBLIC WORKS STANDARD DRAWING		REV. DATE: JULY 2024	REVISION 2
	SEWAGE PUMPING STATION TYPE IV P&ID 1 OF 2		APPROVED BY MM	DRAWN BY ERAMOSA
			STD. DWG. NUMBER SPS-306	SCALE Not to Scale