

New and revised asset classes and asset levels of service

Service	Asset Class	Current Asset Level of Service (If applicable)	Proposed Change	Reason	New Asset Level of Service (if applicable)
Stormwater Management	Minor Culverts	N/A	New Asset Class	Incorporate Minor Culverts in CAM	Maintain Condition Grade = 2
Information Technology	End User Devices	N/A	New Asset Class	Incorporate Information Technology Assets in CAM	Maintain Equipment at a Condition Rating = B (Good)
	Network Infrastructure	N/A	New Asset Class	Incorporate Information Technology Assets in CAM	Maintain Equipment at a Condition Rating = B (Good)
Roads Infrastructure	Signalized Intersection	N/A	New Asset Class	Incorporate Signalized Intersections in CAM	Maintain Structures in Good Condition
Operations Yards Fleet and Equipment	High Consumption Water Meters	N/A	New Asset Class	Incorporate Water Meters in CAM	Maintain Equipment at a Condition Rating = B (Good)
	Transmitters	N/A	New Asset Class	Incorporate Water Meters in CAM	Maintain Equipment at a Condition Rating = B (Good)
	Commercial Water Meters	N/A	New Asset Class	Incorporate Water Meters in CAM	Maintain Equipment at a Condition Rating = B (Good)
	Residential Water Meters	N/A	New Asset Class	Incorporate Water Meters in CAM	Maintain Equipment at a Condition Rating = B (Good)

Service	Asset Class	Current Asset Level of Service (If applicable)	Proposed Change	Reason	New Asset Level of Service (if applicable)
Water Supply	Intake	Backup capacity for all critical equipment (electrical and mechanical): Provide sufficient redundant screen capacity. Able to meet average day capacity with largest unit out of service.	Change Asset Level of Service name: Backup capacity for all critical equipment (electrical and mechanical): Provide sufficient redundant screen capacity. Able to meet max day demand with largest unit out of service.	To better align with current service delivery standards	N/A
	Intake	Secondary intake gate	Change Asset Level of Service name: Secondary Intake Gate in intake well	To better align with current service delivery standards	N/A
	Intake	Provide redundant power supply	Change Asset Level of Service name: Provide emergency standby power supply	To better align with current service delivery standards	N/A
	Pre-Treatment	Provide redundant power supply	Change Asset Level of Service name: Provide emergency standby power supply	To better align with current service delivery standards	N/A
	Water Disinfection	Provide redundant power supply	Change Asset Level of Service name: Provide emergency standby power supply	To better align with current service delivery standards	N/A
	Filtration	Provide redundant power supply	Change Asset Level of Service name: Provide emergency standby power supply	To better align with current service delivery standards	N/A
	Chemical Systems	Provide redundant power supply	Change Asset Level of Service name: Provide emergency standby power supply	To better align with current service delivery standards	N/A
	High Lift Pumps	Provide redundant power supply	Change Asset Level of Service name: Provide emergency standby power supply	To better align with current service delivery standards	N/A
	Plant Wide Support Systems	Provide redundant power supply	Change Asset Level of Service name: Provide emergency standby power supply	To better align with current service delivery standards	N/A