ANSI C Title Block Revision A. Designed by Eric Leitner. ©2025 Peel Region. All Rights Reserved.

Print Date: 2025-08-22 12:28:38 PM

C:\Users\eric.leitner\OneDrive - Cima+\Documents\CIMA+ Projects\Peel Standards\18-2108-002-000-E-6001

Fuses / Breakers

- 15A Fuse
- 15A Fuse (S)
- 15A Thermal Overload
- 15A Circuit Interrupter (1 Pole)
- 15A Circuit Interrupter (3 Pole)
- 15A Circuit Breaker 1 Pole - Thermal
- 15A Circuit Breaker 3 Pole - Thermal
- 15A Magnetic Trip
- 15A Circuit Breaker 1 Pole - Magnetic
- 15A Circuit Breaker 3 Pole - Magnetic

Alarms

- Bell
- Horn/Siren
- Buzzer
- Camera
- Camera w/ Pan and Tilt

Relay Devices

- 25 Sync Check
- 25A Automatic Synchroniser
- 32 Reverse Power
- 49 Thermal Overload
- 50/51 G Timed Inst/Grd Over Current
- 50 Instantaneous Over Current
- 51 Timed Over Current
- 63 G Tank Sudden Pressure
- 63 Q Liquid Level
- 86 Lockout
- 87 Differential Protective

Switches

- Momentary NO
- Momentary NC
- Momentary NO/NC
- Toggle, 2 Position
- Toggle, 3 Position
- SPST NO (a)
- SPST NO (b)
- SPST NC (a)
- SPST NC (b)
- SPDT
- Rotary Selector 5 Position

Transformer

- 600 / 220 V

Actuators

- Pressure
- Differential Pressure
- Liquid Level
- Temperature
- Flow
- Foot
- 0:20 ON Time Delay
- 0:20 OFF Time Delay

Relay Contacts

- Contact NO
- Contact NC
- Contact NO/NC

XC: Contactor
BC: Bypass Contactor
CC: Capacitor Contactor
IC: Inline Contactor

Battery (Cells)

Pilot Light

See ANSI/ISA-5.1-2024 Table 18 for additional notes on the use of Electrical Schematic Symbols.

RESOURCE DRAWING

This resource drawing is based on available records and data supplied by third parties, some of which may not have been verified. It is being provided as a courtesy, without any warranty, express or implied, as to its accuracy or completeness. It may not reflect current site conditions or post-construction changes. It does not include a professional engineer's seal and is not to be considered a certified record drawing. Peel Region makes no representation or guarantee regarding the accuracy of this resource drawing and disclaims any responsibility or liability for loss, damage, or injury resulting from its use. Users are solely responsible for verifying the accuracy and completeness of this resource drawing before relying upon it for any purpose.

Peel Region
working with you

10 Peel Centre Drive
Suites A and B
Brampton, ON L6T 4B9

Peel Vertical CADD Standard

Version 2.0 2025-08-31
Standard Symbol Library

Peel Region Project No. :	Peel Region Contract Number :
18-2108	2022-222vPC10-1-004

Peel Region File Name :
18-2108-002-000-E-6001

Mark	Date	Description
2.0	2025-08-31	Peel Region Approved Edition
G	2025-07-17	ANSI/ISA 5.1 - 2024 Edition
F	2025-06-27	Final Adjustments to Elements
E	2025-02-24	End of April Edition
D	2025-04-10	Updated Edition
C	2025-03-10	Updated Edition

Revision History

Filename :	Version :
18-2108-002-000-E-6001	2025

Consultant Project Number :	Consultant Project Manager :
UDS Module 6	Eric Leitner, PMP
Drawn : Eric Leitner, C.Tech.	Date (yyyy-mm-dd) : 2025-06-27
Checked : Catherine Ledo	Date (yyyy-mm-dd) : 2025-08-31
Approved : James Layhey	Date (yyyy-mm-dd) : 2025-08-31

Title :

Peel Region CADD Standard
Electrical SLD Symbol Legends
ISA 5.1 - 2024 Edition - Table 18

Page Size :	Peel Region Sheet Number:	Rev :
ANSI C	000-E-6001	2.0
Scale : N / A		Sheet : 08 of : 08