

Public Pool and Spa Convictions

Peel Public Health inspects public pools and public spas for compliance with the Health Protection and Promotion Act, 1990 and Public Pools Regulation (Reg.565/90). If a person fails to comply with the legislation, a charge may be laid by a public health inspector.

Below is a list of public pools and spas where an offence occurred and the owner or operator was charged and convicted. Convictions will be posted for two years from the conviction date. This list was last updated on **March 25, 2026**.

To report an error, contact Peel Public Health by email at: peelhealth@peelregion.ca or call at: 905-799-7700 (toll free at 905-584-2216 in Caledon).

To search for a specific business, or address, press "CTRL-F".

Name and Address of Business Where Offence Occurred	Offence	Legislation	Date of Offence (YYYY-MM-DD)	Date of Conviction (YYYY-MM-DD)	Fine
LA Fitness 5077 Dixie Rd Mississauga	Fail to record free available chlorine at least 30 minutes before opening public pool	Public Pools (Reg. 565)	2025-08-11	2026-02-04	\$55

Disclaimer: Peel Public Health takes reasonable efforts to keep the information on this website current and accurate; however, there is no guarantee that the information is complete or free from error.

Public Pool and Spa Convictions

Name and Address of Business Where Offence Occurred	Offence	Legislation	Date of Offence (YYYY-MM-DD)	Date of Conviction (YYYY-MM-DD)	Fine
LA Fitness 5077 Dixie Rd Mississauga	Fail to keep daily record of reading of make-up water meter for pool as of end of day	Public Pools (Reg. 565)	2025-08-11	2026-02-04	\$55
LA Fitness 5077 Dixie Rd Mississauga	Emergency stop button — does not activate visual signal when used	Public Pools (Reg. 565)	2025-08-11	2026-02-04	\$305
LA Fitness 5077 Dixie Rd Mississauga	Emergency stop button — does not activate audible signal when used	Public Pools (Reg. 565)	2025-08-11	2026-02-04	\$305

Disclaimer: Peel Public Health takes reasonable efforts to keep the information on this website current and accurate; however, there is no guarantee that the information is complete or free from error.

Public Pool and Spa Convictions

Name and Address of Business Where Offence Occurred	Offence	Legislation	Date of Offence (YYYY-MM-DD)	Date of Conviction (YYYY-MM-DD)	Fine
LA Fitness 5077 Dixie Rd Mississauga	Where pool has automatic sensing device — fail to check requirements at least every four hours during daily use period	Public Pools (Reg. 565)	2025-08-11	2026-02-04	\$55
LA Fitness 5077 Dixie Rd Mississauga	Fail to add at least 15 litres per bather of make-up water to public pool each operating day as determined by water meter	Public Pools (Reg. 565)	2025-08-11	2026-02-04	\$120
PCC 129 - Class B Outdoor Swimming Pool 900 Central Park Dr Brampton	Fail to ensure public pool water clear enough to permit black disc at deepest point to be clearly visible from point on deck nine m away	Public Pools (Reg. 565/90)	2025-08-06	2025-10-07	\$465

Disclaimer: Peel Public Health takes reasonable efforts to keep the information on this website current and accurate; however, there is no guarantee that the information is complete or free from error.

Public Pool and Spa Convictions

Name and Address of Business Where Offence Occurred	Offence	Legislation	Date of Offence (YYYY-MM-DD)	Date of Conviction (YYYY-MM-DD)	Fine
PCC 129 - Class B Outdoor Swimming Pool 900 Central Park Dr Brampton	Fail to ensure public pool water treated with chlorine, a chlorine compound or bromine by means of chemical feeder	Public Pools (Reg. 565/90)	2025-08-06	2025-10-07	\$465
Class B Outdoor Swimming Pool 1177 Bloor St E Mississauga	Fail to maintain public pool in safe condition	Public Pools (Reg. 565/90)	2024-08-07	2024-09-16	\$465
Class B Outdoor Swimming Pool 1177 Bloor St E Mississauga	Fail to ensure residual of free available chlorine of public pool water maintained between 0.5 – 10 ppm	Public Pools (Reg. 565/90)	2024-08-07	2024-09-16	\$305

Disclaimer: Peel Public Health takes reasonable efforts to keep the information on this website current and accurate; however, there is no guarantee that the information is complete or free from error.

Public Pool and Spa Convictions

Name and Address of Business Where Offence Occurred	Offence	Legislation	Date of Offence (YYYY-MM-DD)	Date of Conviction (YYYY-MM-DD)	Fine
Class B Outdoor Swimming Pool 1177 Bloor St E Mississauga	Operator fail to ensure emergency telephone required for Class B pool tested to confirm operation before pool opened for use	Public Pools (Reg. 565/90)	2024-08-07	2024-09-16	\$55

Disclaimer: Peel Public Health takes reasonable efforts to keep the information on this website current and accurate; however, there is no guarantee that the information is complete or free from error.