



**NOTES**

1. NO EXTRUDED COPPER FITTINGS (SOLDERED) OR GALVANIZED FITTINGS TO BE USED, ALL FITTINGS MUST BE MADE OF BRASS.
2. FOR CORRECT BYPASS INSTALLATION, METER SPACERS ARE AVAILABLE AT 2 COPPER RD., BRAMPTON. PHONE: (905) 791-7800 EXT. 3226.
3. INLET AND OUTLET PORTS TO BE 25mm FOR METER ASSEMBLY.
4. METER SUPPLIED AND INSTALLED BY THE REGION OF PEEL METER DEPARTMENT.
5. REFER TO STD 1-2-3 FOR STAND PIPE.
6. ALL PIPING, FITTINGS AND BACKFLOW PREVENTER SHALL BE SUPPORTED INDEPENDENTLY OF EACH OTHER.



**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: MAY 2026

APPROVED BY

A.M.

STD. DWG. NUMBER

**1-3-9**

DRAWN BY

PEEL CAD TEAM

SCALE

N.T.S.

**25mm BY-PASS FOR  
DETECTOR CHECK VALVE ASSEMBLY  
IN CHAMBER FOR FIRE SERVICES**