



NOTES

1. PROVISION IS TO BE MADE FOR THE DISPOSAL OF WATER THROUGH FLOOR DRAIN.
2. FLANGED ENDS COMPLETE WITH TAPPED BLIND FLANGE.
3. BY-PASS MAY BE ONE PIPE SIZE SMALLER THAN METER SIZE AND MAY BE INSTALLED HORIZONTALLY. NO BALL VALVE SHALL BE USED ON THE BY-PASS.
4. WHERE METER ROOM IS NOT ADJACENT TO AN OUTSIDE WALL OR IS BELOW EXTERIOR FINISHED GRADE, THE CONTRACTOR/APPLICANT SHALL PROVIDE A CONTINUOUS 12mm E.M.T. CONDUIT COMPLETE WITH NYLON FISH LINE FROM METER ROOM TO 1000mm ABOVE EXTERIOR FINISHED GRADE.
5. MIN. 300mm CLEARANCE BETWEEN WALL AND EDGE OF METER.
6. METER SHALL BE ACCESSIBLE AT ALL TIMES.
7. BACKFLOW PREVENTER SHALL BE INSTALLED AFTER BOTH THE METER AND BY-PASS AS PER CSA B64.10-23 AS AMENDED.
8. ALL PIPING, FITTINGS AND METER SHALL BE SUPPORTED INDEPENDENTLY OF EACH OTHER.
9. PIPING SHALL BE BRACED TO MAINTAIN ALIGNMENT OF PIPE AND FITTINGS, PREVENT SWAYING, AND CONTROL THRUST. ALL SUPPORT MATERIALS SHALL BE COMPATIBLE WITH PIPE MATERIAL AND, CORROSION RESISTANT WHEN INSTALLED IN WET ENVIRONMENT.
10. METER ASSEMBLY SHALL BE INSTALLED BETWEEN 300mm AND 914mm FROM THE POINT OF ENTRY OF THE WATER SERVICE INTO THE BUILDING.
11. REMOTE RECEPTACLE TO BE INSTALLED ON THE EXTERIOR WALL OF THE PROPERTY.
12. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: MAY 2026

APPROVED BY

A.M.

STD. DWG. NUMBER

1-4-1

DRAWN BY

PEEL CAD TEAM

SCALE

N.T.S.

**75 TRU-FLO COMPOUND METER
IN BUILDING**