



NOTES

1. IF METER CHAMBER IS LOCATED NEAR THE PROPERTY LINE, VALVE TO BE AT PROPERTY LINE.
2. 50mm GALVANIZED CONDUIT SHALL BE INSTALLED FROM CHAMBER WALL TO A SUITABLE LOCATION 2000 MIN. OUTSIDE TRAFFIC AREA.
3. IF SERVICE IS POLYETHYLENE, THEN BRASS ADAPTORS TO IRON PIPE THREAD SHALL BE SUPPLIED AND INSTALLED FOR METER INSTALLATION.
4. EXTRUDED COPPER (SOLDERED) OR GALVANIZED FITTINGS SHALL NOT BE USED, ALL FITTINGS TO BE BRASS.
5. FOR CORRECT METER INSTALLATION, METER SPACERS ARE AVAILABLE AT 2 COPPER RD. BRAMPTON. PHONE: 905-791-7800 EXT. 3226
6. ALL BARE METAL SERVICES (FITTINGS, PIPING, APPURTENANCES, ETC) TO BE WRAPPED IN AN ANTICORROSION PETROLEUM TAPE INCLUDING PASTE MASTIC AND TAPE.
7. WHERE REQUIRED, BACKFLOW PREVENTER SHALL BE INSTALLED AFTER THE METER AS PER CSA B64.10-23 AS AMENDED.
8. ALL PIPING, FITTINGS AND METER SHALL BE SUPPORTED INDEPENDENTLY OF EACH OTHER.
9. PIPING SHALL BE BRACED TO MAINTAIN ALIGNMENT OF PIPE AND FITTINGS, PREVENT SWAYING, AND CONTROL THRUST. ALL SUPPORT MATERIALS SHALL BE COMPATIBLE WITH PIPE MATERIAL AND, CORROSION RESISTANT WHEN INSTALLED IN WET ENVIRONMENT.
10. ALL CONNECTIONS SHALL BE MADE DOWNSTREAM OF THE BACKFLOW PREVENTER AT BUILDING(S).
11. NO CONNECTION SHALL BE MADE BETWEEN METER AND BACKFLOW PREVENTER.
12. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.



PUBLIC WORKS STANDARD DRAWING

REV. DATE: MAY 2026

APPROVED BY

A.M.

STD. DWG. NUMBER

1-4-12

DRAWN BY

PEEL CAD TEAM

SCALE

N.T.S.

16mm x 19mm TO 25mm DOMESTIC WATER SERVICE
METER IN CHAMBER