



NOTES

1. IF METER CHAMBER IS LOCATED NEAR THE STREET LINE, VALVE TO BE AT STREET LINE.
2. 50mm GALVANIZED CONDUIT SHALL BE INSTALLED FROM INSIDE CHAMBER WALL TO SUITABLE LOCATION, LOCATED A MINIMUM OF 2000mm FROM PARKING LOTS, DRIVEWAYS, SIDEWALKS OR OTHER TRAVELLED SURFACES AS PER STD DWG 1-2-3.
3. BLIND FLANGE OR M.J. PLUG TAPPED TO SUIT.
4. BY-PASS MAY BE ONE SIZE SMALLER THAN METER SIZE.
5. ALL BARE METAL SERVICES (FITTINGS, PIPING, APPURTENANCES, ETC) TO BE WRAPPED IN AN ANTICORROSION PETROLEUM TAPE INCLUDING PASTE MASTIC AND TAPE.
6. BACKFLOW PREVENTER SHALL BE INSTALLED AFTER BOTH THE METER AND BY-PASS AS PER CSA B64.10-23 AS AMENDED.
7. NO CONNECTION SHALL BE MADE BETWEEN THE BACKFLOW PREVENTER AND THE METER ASSEMBLY.
8. PIPING SHALL BE BRACED TO MAINTAIN ALIGNMENT OF PIPE AND FITTINGS, PREVENT SWAYING, AND CONTROL THRUST. ALL SUPPORT MATERIALS SHALL BE COMPATIBLE WITH PIPE MATERIAL AND, CORROSION RESISTANT WHEN INSTALLED IN WET ENVIRONMENT.
9. ALL PIPING, FITTINGS AND METER SHALL BE SUPPORTED INDEPENDENTLY OF EACH OTHER.
10. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: JUNE 2026

APPROVED BY

A.M.

STD. DWG. NUMBER

1-4-2

DRAWN BY

PEEL CAD TEAM

SCALE

N.T.S.

**75mm TRU-FLO DOMESTIC ONLY
COMPOUND METER IN CHAMBER**