



SECTION 'A'

NOTES

1. A 12 GAUGE TRACER WIRE TO BE INSTALLED WITH THE PIPE AND BE BROUGHT TO THE SURFACE AT ALL VALVE BOX BOXES, AS PER STD. DWG. 1-3-8.
2. BACKFILL TRENCH WITH GRANULAR 'B' COMPACTED TO 100% STD. PROCTOR DENSITY.
3. BACKFLOW PREVENTERS SHALL BE INSTALLED AS PER CSA B64. 10-23 AS AMENDED.
4. ALL BARE METAL SERVICES (FITTINGS, PIPING, APPURTENANCES, ETC) TO BE WRAPPED IN AN ANTICORROSION PETROLEUM TAPE SYSTEM INCLUDING PASTE MASTIC AND TAPE.
5. WATER SERVICES EQUAL IN DIAMETER TO THE MAIN SHALL BE INSTALLED WITH AN ANCHOR TEE; SMALLER SERVICES SHALL BE INSTALLED BY LIVE TAP. ALL INSTALLATIONS REQUIRE A VALVE AND A VALVE BOX.
6. WATER VALVE TO BE FLANGED TO THE ANCHOR TEE OR TO THE TAPPING SLEEVE OR SADDLE.
7. ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: MAY 2026

APPROVED BY

D.L.

STD. DWG. NUMBER

1-6-4

DRAWN BY

PEEL CAD TEAM

SCALE

N.T.S.

FIRE LINE AND DOMESTIC CONNECTION